


Monroe County Water Authority
475 Norris Drive
Rochester, New York 14610



MCWA Annual Water Quality Report



MCWA Shoremont W.D. PWSID# 2701047
MCWA Upland W.D. PWSID# 2715672
MCWA Genesee PWSID# 1800547



The **Monroe County Water Authority** is pleased to provide you this report on the quality of your drinking water which describes its sources, treatment and test results.



2008 Annual Water Quality Report

MCWA — Water Quality Table

2008 results except as noted											
Detected Substances	Supply (Source)	Units	MCLG	MCL	Shoremont WTP (L.Ontario)	Corfu WTP (Well)	Purchased Water Hemlock WTP (Hemlock L.)	Purchased Water C.Batavia WTP (Well & Tonawanda Cr.)	Purchased Water ECWA (L. Erie & Niagara R.)	Purchased Water T.Ontario WTP (L.Ontario)	Meets EPA Standards
Substances	Units	MCLG	MCL	Range of detected values						Likely Source	
Barium	mg/L	2	2	0.019 - 0.022	0.052 - 0.088	0.015 - 0.019	0.015	0.020 - 0.023	0.024	Erosion of natural deposits	Yes
Chloride	mg/L	NA	250	24 - 27	40 - 44	34 - 73	90	22 - 48	NR	Naturally occurring	Yes
Fluoride	mg/L	NA	2.2	0.3 - 1.4	NR	0.2 - 1.0	0.1 - 1.1	0.2 - 1.0	0.8 - 1.1	Natural and additive - promotes strong teeth	Yes
Manganese	ug/L	NA	300	ND	4.2 - 5.8	ND	ND	2.2 - 11	NR	Naturally occurring	Yes
Nitrate	mg/L	10	10	0.36 - 0.45	ND	0.015 - 0.6	0.88	0.11 - 0.33	0.63	Erosion of natural deposits	Yes
Sodium	mg/L	NA	NS	13	110	18	44	14 - 16	NR	Naturally occurring	Yes
Sulfate	mg/L	NA	250	27 - 29	56 - 57	14 - 17	39	24	NR	Naturally occurring	Yes
Radionuclides Gross Alpha	pCi/L	NA	15	ND (2003)	ND (2003)	ND (2001)	0.029 (2000)	ND-1.7 (2004)	ND (2007)	Erosion of natural deposits	Yes
Radionuclides Gross Beta	pCi/L	NA	50	ND (2003)	ND (2003)	ND (2001)	1.2 (2000)	ND-2.2 (2004)	ND (2007)	Decay of natural deposits and man-made emissions	Yes
Organics, Pesticides, Herbicides											
Caffeine	ng/L	NS	NS	4	NR	ND	NR	NR	NR	Pharmaceutical	Yes
Cotinine	ng/L	NS	NS	2.1	NR	1.7	NR	NR	NR	Pharmaceutical	Yes
Triclosan	ng/L	NS	NS	ND	NR	5.8	NR	NR	NR	Personal care products	Yes
Di(2-Ethylhexyl)phthalate	ug/L	0	6	ND	ND	ND	0.9	ND	ND	Plastic production and disposal	Yes
Treatment Requirements - 95% of samples each month must be less than 0.3 NTU. Range and lowest monthly percentage are listed. Turbidity is a measure of water clarity and is used to gauge filtration performance.											
Turbidity - Entry Point	NTUs	NA	TT	0.04 - 0.13 100%	NA	0.04 - 0.29 100%	0.01 - 0.05 100%	0.07 - 0.19 100%	0.02 - 0.07 100%	Soil runoff	Yes
Microbial - No more than 5% of monthly samples can be positive. The highest monthly % positive is listed.											
Coliform	% Positive	0	5%	0.4% Aug	2.6% Aug	0.9% May	ND	2.6% Aug	ND	Naturally occurring	Yes
Disinfectant and Disinfectant By-products (DBPs) - Average and Range are listed. * Chlorine has a MDRL (Maximum Disinfectant Residual Level) and MDRLG (MDRL Goal) rather than an MCL and MCLG.											
Chlorine Residual - Entry Pt	mg/L	4 *	4 *	1.0 (0.7-1.5)	0.8 (0.05-1.0)	0.9 (0.7-1.5)	0.5 (0.2 - 0.8)	0.9 (0.2 - 1.5)	0.9 (0.8-1.0)	Additive for control of microbes	Yes
Total THMs	ug/L	NA	80	38 (16-68)	42 (20-62)	38 (25-68)	39 (23-47)	42 (20-62)	26 (44-10)	By-product of water chlorination	Yes
Haloacetic Acids	ug/L	NA	60	8 (2-25)	11 (2-21)	17 (2-32)	7 (4-9.8)	11 (2-21)	8 (1-19)	By-product of water chlorination	Yes
Lead and Copper - 90% of samples must be less than the Action Level (AL). 90th Percentile and the number of samples exceeding AL are listed.											
Copper (Customer Tap Samples)	mg/L	1.3	AL=1.3	0.091 None (2006)	0.25 None (2006)	0.091 None (2006)	0.052 None (2007)	0.25 None (2006)	0.068 None	Corrosion of household plumbing	Yes
Lead (Customer Tap Samples)	ug/L	0	AL=15	4.8 None (2006)	3 None (2006)	4.8 None (2006)	1.8 None (2007)	3 None (2006)	2.4 None	Corrosion of household plumbing	Yes

Note: The following contaminants were tested for but not found: 1,1,1,2-Tetrachloroethane, 1,1,1-Trichloroethane, 1,1,2,2-Tetrachloroethane, 1,1,2-Trichloroethane, 1,1-Dichloroethene, 1,1-Dichloropropene, EDB, 1,2,3-Trichlorobenzene, 1,2,3-Trichloropropane, 1,2,4-Trichlorobenzene, 1,2,4-Trimethylbenzene, 1,2-Dichlorobenzene, 1,2-Dichloroethane, 1,2-Dichloropropane, 1,3,5-Trimethylbenzene, 1,3-Dichlorobenzene, 1,3-Dichloropropane, 1,3-Dichloropropene (Cis), 1,3-Dichloropropene (Trans), 1,3-dinitrobenzene, 1,4-Dichlorobenzene, 2,2-Dichloropropane, 2,2,4,4-tetrabromodiphenyl ether, 2,2,4,4,5,5-hexabromodiphenyl ether, 2,2,4,4,5,5-hexabromobiphenyl, 2,2,4,4,5,5-pentabromodiphenyl ether, Dioxin, 2,4 D, 2-4-5 TP, 2,4,6-trinitrotoluene (TNT), 2-Chlorotoluene, 3-Hydroxycarbofuran, 4,4'-DDT, 4-Chlorotoluene, Acetochlor, Acetominophen, Aldicarb Sulfone, Aldicarb Sulfoxide, Aldrin, Aluminum, Antimony, Arsenic, Atrazine, Benzene, Benzo(a)pyrene, Beryllium, Bromobenzene, Bromochloromethane, Bromomethane, Butachlor, Cadmium, Carbamazepine, Carbaryl, Carbofuran, Carbon Tetrachloride, Chlordane, Chlorobenzene, Chloroethane, Chloromethane, Chromium, cis-1,2-Dichloroethene, Cryptosporidium, Cyanide, DCPA, Dalapon, DBCP, Di(2-Ethylhexyl) Adipate, Diazepam, Dibromomethane, Dicamba, Dichlorodifluoromethane, Dichloromethane (Methylene Chloride), Dieldrin, Dimethoate, Dinoseb, Diquat, Endothall, Endrin, Estrone, Estradiol, Ethinyl Estradiol, Ethylbenzene, Fluoxetine, Gemfibrozil, Glyphosate, Gross Alpha, Giardia, Gross Beta, Heptachlor, Heptachloroepoxide, Hexachlorobenzene, Hexachlorobutadiene, Hexachlorocyclopentadiene, Ibuprofen, Iron, Isophorone, Isopropyl Benzene, Lindane, Iopromide, Mercury, Methomyl, Methoxychlor, Metolachlor, Metribuzin, Mirex, MTBE, n-Butylbenzene, Nickel, Nitrite, N-nitroso-di-n-butylamine, N-nitroso-di-n-propylamine, N-nitroso-diethylamine, N-nitroso-dimethylamine, N-nitroso-methylethylamine, N-nitroso-pyrrolidine, n-Propylbenzene, Oxamyl, PCB's, Pentachlorophenol, Pichloram, p-Isopropyltoluene, Progesterone, Propachlor, RDX, sec-Butylbenzene, Selenium, Silver, Simazine, Styrene, Sulfamethoxazole, Terbufos sulfone, tert-Butylbenzene, Testosterone, Tetrachloroethene, Thallium, Toluene, Toxaphene, trans-1,2-Dichloroethene, Trichloroethene, Trichlorofluoromethane, Trimethoprim, Tritium, Vinyl Chloride, Xylene, Zinc

Key Terms Used In Water Quality Table

MCL = Maximum Contaminant Level, the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as possible.

MCLG = Maximum Contaminant Level Goal, the level of a contaminant below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL = Maximum Residual Disinfectant Level, the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG = Maximum Residual Disinfectant Level Goal, the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

TT = Treatment Technique, a required process intended to reduce the level of a contaminant in drinking water.

AL = Action Level, the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ND = Not Detected, absent or present at less than testing method detection level. All testing methods are EPA approved with detection limits much less than the MCL.

NA = Not applicable NR = Not Required NS = No standard

mg/L = milligram (1/1,000 of a gram) per liter = ppm = parts per million

ug/L = microgram (1/1,000,000 of a gram) per liter = ppb = parts per billion

ng/L = nanogram (1/1,000,000,000 of a gram) per liter = ppt = parts per trillion

NTU = Nephelometric Turbidity Unit, a measure of water clarity.

pCi/L = Picocuries per liter, a measure of the radioactivity in water.

A detailed summary of our monitoring program is available on our website at www.mcwa.com or through Customer Service at 442-7200.