

MCWA - Water Quality Table

Detected Substances										2013 results except as noted
Supply (Source)				Shoremont & Webster WTPs (L.Ontario)	Corfu WTP (Well)	Purchased Water Hemlock WTP (Hemlock L.)	Purchased Water ECWA (L. Erie & Niagara R.)			Meets EPA Standards
Substances	Units	MCLG	MCL	Range of detected values				Likely Source		
Barium	mg/L	2	2	0.018 - 0.023	0.11 - 0.13	0.014 - 0.017	0.019 - 0.021	Erosion of natural deposits	Yes	
Chloride	mg/L	NA	250	23 - 34	42 - 70	33 - 34	20 - 26	Naturally occurring	Yes	
Chromium	ug/L	100	100	ND	ND - 1	ND	ND	Naturally occurring	Yes	
Fluoride	mg/L	NA	2.2	0.2 - 1.1	NR	0.05 - 0.9	0.1 - 1.0	Natural and additive - promotes strong teeth	Yes	
Manganese	ug/L	NA	300	ND	7 - 10	ND	ND - 5	Naturally occurring	Yes	
Nitrate	mg/L	10	10	0.13 - 0.34	ND	ND - 0.18	ND - 0.28	Erosion of natural deposits	Yes	
Sodium	mg/L	NA	NS	26-28	47 - 80	19	12 - 16	Naturally occurring	Yes	
Sulfate	mg/L	NA	250	26 - 28	50	14	22	Naturally occurring	Yes	
Treatment Requirements - 95% of samples each month must be less than 0.3 NTU. Range and lowest monthly percentage are listed. Turbidity is a measure of water clarity and is used to gauge filtration performance.										
Turbidity - Entry Point	NTUs	NA	TT	0.03 - 0.10 (100%)	NR	0.04 - 0.15 (100%)	0.06 - 0.23 (100%)	Soil Runoff	Yes	
Microbial - No more than 5% of monthly samples can be positive. The highest monthly % positive is listed.										
Coliform	% Positive	0	5%	0.3% June	ND	0.3% June	ND	Naturally occurring	Yes	
Disinfectant and Disinfectant By-products (DBPs) - Chlorine has a MRDL (Maximum Residual Disinfectant Level) and MRDLG (MRDL Goal) rather than an MCL and MCLG (Average and range are listed). For the DBPs (THMs and Haloacetic acids) the highest individual location annual average and the range for all locations are listed.										
Chlorine Residual - Entry Pt	mg/L	4	4	1.1 (0.3 - 1.5)	0.7 (0.5 - 1.0)	0.9 (0.6 - 1.3)	1.5 (0.5 - 2.0)	Additive for control of microbes	Yes	
Total THMs	ug/L	NA	80	62 (16- 93)	52 (15 - 64)	62 (16- 93)	52 (15 - 64)	Byproduct of water chlorination	Yes	
Haloacetic Acids	ug/L	NA	60	19 (ND - 31)	11 (ND - 21)	19 (ND - 31)	11 (ND - 21)	Byproduct of water chlorination	Yes	
Lead and Copper - 90% of samples must be less than the Action Level (AL). The 90th Percentile, the number of samples exceeding the AL, and the range of results are listed.										
Copper (Customer Tap Samples)	mg/L	1.3	AL=1.3	0.118 (None) 0.012 - 0.320 (2012)	0.160 (None) 0.003 - 0.33 (2012)	0.118 (None) 0.012 - 0.320 (2012)	0.160 (None) (2012)	Corrosion of household plumbing	Yes	
Lead (Customer Tap Samples)	ug/L	0	AL=15	4.9 (None) ND - 0.015 (2012)	ND (None) ND - 0.0016 (2012)	4.9 (None) ND - 0.015 (2012)	ND (None) (2012)	Corrosion of household plumbing	Yes	

Key Terms Used In Water Quality Table

MCL = Maximum Contaminant Level, the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as possible.

MCLG = Maximum Contaminant Level Goal, the level of a contaminant below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL = Maximum Residual Level, the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG = Maximum Residual Disinfectant Level Goal, the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

pCi/L = picoCuries per liter

TT = Treatment Technique, a required process intended to reduce the level of a contaminant in drinking water.

AL = Action Level, the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ND = Not Detected, absent or present at less than testing method detection level. All testing methods are EPA approved with detection limits much less than the MCL.

NA = Not applicable **NR** = Not Required **NS** = No standard

mg/l = milligram (1/1,000 of a gram) per liter = ppm = parts per million

ug/l = microgram (1/1,000,000 of a gram) per liter = ppb = parts per billion

ng/L = nanogram (1/1,000,000,000 of a gram) per liter = ppt = parts per trillion

NTU = Nephelometric Turbidity Unit, a measure of water clarity.

Note: The following contaminants were tested for but not found: 1,1,1,2-Tetrachloroethane, 1,1,1-Trichloroethane, 1,1,2,2-Tetrachloroethane, 1,1,2-Trichloroethane, 1,1-Dichloroethene, 1,1-Dichloropropene, EDB, 1,2,3-Trichlorobenzene, 1,2,3-Trichloropropane, 1,2,4-Trichlorobenzene, 1,2,4-Trimethylbenzene, 1,2-Dichlorobenzene, 1,2-Dichloroethane, 1,2-Dichloropropane, 1,3,5-Trimethylbenzene, 1,3-Dichlorobenzene, 1,3-Dichloropropane, 1,3-Dichloropropene(Cis), 1,3-Dichloropropene(Trans), 1,3-dinitrobenzene, 1,4-Dichlorobenzene, 2,2-Dichloropropane, Dioxin, 2,4 D, 2,4-5 TP, 2,4,6-trinitrotoluene (TNT), 2-Chlorotoluene, 3-Hydroxycarbofuran, 4,4'-DDD, 4,4'-DDE, 4,4'-DDT, 4-Chlorotoluene, Acetochlor, Acetaminophen, Aldicarb Sulfone, Aldicarb Sulfoxide, Aldrin, Aluminum, Antimony, Arsenic, Atrazine, Benzene, Benzo(a)pyrene, Beryllium, Bromobenzene, Bromochloromethane, Bromomethane, Butachlor, Cadmium, Carbamazepine, Carbaryl, Carbofuran, Carbon Tetrachloride, Chlordane, Chlorobenzene, Chloroethane, Chloromethane, Chromium, cis-1,2-Dichloroethene, Cryptosporidium, Cyanide, DCPA, Dalapon, DBCP, Di(2-Ethylhexyl) Adipate, Di(2-Ethylhexyl) Phthalate, Diazepam, Dibromomethane, Dicamba, Dichlorodifluoromethane, Dichloromethane, Dieldrin, Dimethoate, Dinoseb, Diquat, Endothal, Endrin, Estrone, Estradiol, Ethinyl Estradiol, Ethylbenzene, Fluoxetine, Gemfibrozil, Giardia, Glyphosate, Gross Alpha, Gross Beta, Heptachlor, Heptachlorepoixide, Hexachlorobenzene, Hexachlorobutadiene, Hexachlorocyclopentadiene, Ibuprofen, Iron, Isophorone, Isopropyl Benzene, Lindane, Iopromide, Manganese, Mercury, Methomyl, Methoxychlor, Metolachlor, Metribuzin, MTBE, n-Butylbenzene, Nickel, Nitrite, n-Propylbenzene, Oxamyl, Paraquat, PCB's, Pentachlorophenol, Perchlorate, Pichloram, p-Isopropyltoluene, Progesterone, Propachlor, RDX, sec-Butylbenzene, Selenium, Silver, Simazine, Styrene, Sulfamethoxazole, Surfactants, Terbufos sulfone, tert-Butylbenzene, Testosterone, Tetrachloroethene, Thallium, Toluene, Toxaphene, trans-1,2-