

MCWA—Water Quality Table

Detected Substances											2006 results except as noted	
Supply (Source)				Shoremont WTP (L.Ontario)	Corfu WTP (Well)	Purchased Water Hemlock WTP (Hemlock L.)	Purchased Water C.Batavia WTP (Well &)	Purchased Water ECWA (L. Erie & Niagara R.)	Purchased Water T.Ontario WTP (L.Ontario)		Meets EPA Standards	
Substances	Units	MCLG	MCL	Range of detected values						Likely Source		
Barium	mg/L	2	2	0.02-0.024	0.046-0.08	0.017-0.019	0.012	0.021-0.023	0.024	Erosion of natural deposits	Yes	
Chloride	mg/L	NA	250	25 - 26	36 - 59	32 - 34	70	22 - 27	NR	Naturally occurring	Yes	
Chromium	ug/L	100	100	ND	ND - 3.8	ND	ND	ND	NR	Erosion of natural deposits	Yes	
Fluoride	mg/L	NA	2.2	0.2 -1.2	NR	ND - 1.0	0.04-1.3	0.5 - 1.0	0.8	Natural and additive - promotes	Yes	
Manganese	ug/L	NA	300	ND - 0.93	4.7 - 7.7	ND	0.01	ND - 3.7	NR	Naturally occurring	Yes	
Nickel	ug/L	NA	NS	ND - 0.6	ND	ND - 0.5	ND	ND - 0.9	2.5	Naturally occurring	Yes	
Nitrate	mg/L	10	10	0.28 - 0.52	ND	0.2 - 0.44	0.88	0.27 - 0.42	0.48	Erosion of natural deposits	Yes	
Sodium	mg/L	NA	NS	11 - 13	69 - 130	19	37	10 - 13	NR	Naturally occurring	Yes	
Sulfate	mg/L	NA	250	28 - 29	62	17	38	24	NR	Naturally occurring	Yes	
Radionuclides Gross Alpha	mg/L	NA	15	ND (2003)	ND (2003)	ND (2001)	0.029(2000)	ND-1.7(2004)	0.47 (2003)	Erosion of natural deposits	Yes	
Radionuclides Gross Beta	mg/L	NA	50	ND (2003)	ND (2003)	ND (2001)	1.2(2000)	ND-2.2(2004)	1.1 (2003)	Decay of natural and man-made	Yes	
Organics, Pesticides, Herbicides												
Atrazine	ug/L	3	3	ND	ND	ND	ND	ND - 0.1	ND	Runoff from cropland	Yes	
Treatment Requirements - 95% of samples each month must be less than 0.3 NTU. Range and lowest monthly percentage are listed. Turbidity is a measure of water clarity and is used to gauge filtration performance.												
Turbidity - Entry Point	NTUs	NA	TT	0.03 - 0.14 100%	0.05 - 0.62 NA	0.05 - 0.20 100%	0.01 - 0.14 100%	0.06 - 0.41 NA	0.04 - 0.12 100%	Soil runoff	Yes	
Microbial - No more than 5% of monthly samples can be positive. The highest monthly % positive is listed.												
Coliform	% Positive	0	5%	0.7% May	ND	ND	ND	ND	ND	Naturally occurring	Yes	
Disinfectant and Disinfectant By-products (DBPs) - Average and Range are listed. * Chlorine has a MDRL (Maximum Disinfectant Residual Level) and MDRLG (MDRL Goal) rather than an MCL and MCLG.												
Chlorine Residual- Entry Pt	mg/L	4 *	4 *	1.1 (0.8-1.6)	0.8 (0.5-1.5)	1.0 (0.05-1.2)	0.6 (0.2-0.9)	1.0 (0.4 -1.7)	0.8 (0.8 - 1.0)	Additive for control of microbes	Yes	
Total THMs	ug/L	NA	80	37 (17-66)	44 (24 - 60)	35 (22-53)	52 (30-69)	43 (24-61)	36 (29-45)	By-product of water chlorination	Yes	
Haloacetic Acids	ug/L	NA	60	13 (2-31)	22 (5-37)	23 (9-38)	13 (8-16)	22 (5-37)	9 (5-14)	By-product of water chlorination	Yes	
Lead and Copper - 90% of samples must be less than the Action Level (AL). 90th Percentile and the number of samples exceeding AL are listed.												
Copper (Customer Tap Samples)	mg/L	1.3	AL=1.3	0.091 None	None None	0.025 None	0.091 None	0.052 None	0.25 None	0.106 None (2005)	Corrosion of household plumbing	Yes
Lead (Customer Tap Samples)	ug/L	0	AL=15	4.8 None	3 None	4.8 None	1.8 None	3 None	6 None (2005)	Corrosion of household plumbing	Yes	

Key Terms Used In Water Quality Table

MCL = Maximum Contaminant Level, the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as possible.

MCLG = Maximum Contaminant Level Goal, the level of a contaminant below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL = Maximum Residual Level, the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG = Maximum Residual Disinfectant Level Goal, the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

pC/L = picoCuries per liter

TT = Treatment Technique, a required process intended to reduce the level of a contaminant in drinking water.

AL = Action Level, the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ND = Not Detected, absent or present at less than testing method detection level. All testing methods are EPA approved with detection limits much less than the MCL..

NA = Not applicable

NR = Not Required

NS = No standard

mg/l = milligram (1/1,000 of a gram) per liter = ppm = parts per million

ug/l = microgram (1/1,000,000 of a gram) per liter = ppb = parts per billion

NTU = Nephelometric Turbidity Unit, a measure of water clarity.

Note: The following contaminants were tested for: 1,1,1,2-Tetrachloroethane, 1,1,1-Trichloroethane, 1,1,2,2-Tetrachloroethane, 1,1,2-Trichloroethane, 1,1-Dichloroethene, 1,1-Dichloropropene, EDB,1,2,3-Trichlorobenzene, 1,2,3Trichloropropane, 1,2,4-Trichlorobenzene, 1,2,4-Trimethylbenzene, 1,2-Dichlorobenzene, 1,2-Dichloroethane, 1,2-Dichloropropane, 1,3,5, Trimethylbenzene, 1,3-Dichlorobenzene, 1,3-Dichloropropane, 1,3-Dichloropropene(Cis), 1,3-Dichloropropene(Trans) , 1,4-Dichlorobenzene, 2,2-Dichloropropane, Dioxin, 2,4 D, 2-4-5 TP, 2-Chlorotoluene, 3-Hydroxycarbofuran, 4,4'-DDT, 4-Chlorotoluene, Aldicarb Sulfone, Aldicarb Sulfoxide, Aldrin, Aluminum, Antimony, Arsenic, Atrazine, Barium, Benzene, Benzo(a)pyrene, Beryllium, Bis(2-Ethylhexyl)Phthalate, Bromobenzene, Bromochloromethane, Bromomethane, Butachlor, Cadmium, Carbaryl, Carbofuran, Carbon Tetrachloride, Chlordane, Chlorobenzene , Chloroethane, Chloromethane, Chromium, cis-1,2-Dichloroethene, Cryptosporidium, Cyanide, DCPA, Dalapon, DBCP, Di(2-Ethylhexyl) Adipate, Dibromomethane, Dicamba, Dichlorodifluoromethane, Dichloromethane (Methylene Chloride), Dieldrin, Dinoseb, Diquat, Endothall, Endrin, Ethylbenzene, Glyphosate, Gross Alpha, Giardia, Gross Beta, Heptachlor, Heptachlorepoxyde, Hexachlorobenzene, Hexachlorobutadiene, Hexachlorocyclopentadiene, Isophorone, Isopropyl Benzene, Lindane, Manganese, Mercury, Methomyl, Methoxychlor, Metolachlor, Metribuzin, Mirex, MTBE, n-Butylbenzene, Nickel, Nitrite, n-Propylbenzene, Oxamyl , PCB's, Pentachlorophenol, Pichloram, p-Isopropyltoluene, Propachlor , sec-Butylbenzene, Selenium, Silver, Simazine , Styrene, tert-Butylbenzene, Tetrachloroethene, Thallium, Toluene, Toxaphene, trans-1,2-Dichloroethene, Trichloroethene, Trichlorofluoromethane, Tritium, Vinyl Chloride, Xylene, Zinc

For more information on MCWA's monitoring program call Customer Service at 585-442-7200.